

**ADITYA ENVIRONMENTAL SERVICES PVT. LTD.**Testing Laboratory is certified by **ISO 9001:2015&ISO 45001:2018**

Recognized under The Environment (Protection) Act, 1986" valid up to 24.04.2027

Laboratory: P-1, MIDC Mohopada, Rasayani, Dist. Raigad, 410222, E-mail: pglab@aespl.co.inTel: 9112844844, CIN: U74999MH2001PTC132101 **UDYAM**-MH-19-0029787

TC-7085

**Test Report
(Microbiology - Water)****Ref. No.:** AESPL/LAB/B/Mw-26/08/238**Issue Date:** 27/08/2026

Name of Customer	:	Renaissance Spaces		
Name of Site	:	The Baya Sunrise, Abhinav, Naigaon Dadar (E). Proposed Cluster Redevelopment Scheme CDS Under Regn.33(9) Of DCPR 2034 C.S.Nos.108(pt), 111(pt), 112(pt), 255, 256(pt) & 257(pt) Of Dadar Naigaon Division, Naigaon Estate Scheme No.60, Morbaug Naigaon Estate In 'F/SOUTH' WARD, MUMBAI- 400 014		
Nature of Sample	:	Drinking water	Location of Sample	: Labour Camp
Date of Sample Drawn	:	24/08/2026	Time of Sample Drawn	: 09:40 am
Sample Drawn By	:	ACD	Transported By	: ACD
Date of Sample Receipt	:	24/08/2026	Sample Identification	: Mw- 26/08/238
Sample Quantity & Container	:	250 ml; Glass bottle.		
Date of Sample Analysis	:	24/08/2026 to 25/08/2026		
Environmental Conditions at site	:	Surrounding area is clear.		
Transportation Condition	:	Water Temperature: < 6°C, Cold storage.		
Project/ Job number	:	RS/AB/33/25-26, dtd 19 August 2025		
Reference of Sampling	:	AESPL/LAB/QR/7.3.3/R-03		
Method of Sampling & Preservation	:	AESPL/LAB/SOP/7.3.1/M-01		
Environmental Condition while Testing	:	Ambient Temperature: 23.1°C and Humidity: 57 %		
Sr. No.	Parameter, Unit	Result	Limits as per: IS 10500:2012	Method of Analysis
1.	Coliform/100ml	Absent /100ml	Absent /100ml	IS:15185:2016
2.	E.coli/100ml	Absent /100ml	Absent/100ml	IS:15185:2016

Conformity Statement: Water sample is **Pass** as per IS 10500: 2012 w. r. t. above mentioned tests.**Note:**

1. The test report shall not be reproduced except in full, without written approval of laboratory.
2. Results relate only to the items tested.
3. Data provided by customer and results apply to the sample as received.

**Himani P. Joshi
(Report Reviewed By)****N. K. Shendye
(Authorized Signatory)**

-End of Test Report-